



Fachausschuss Elektrotechnik
Prüf- und Zertifizierungsstelle
im BG-PRÜFZERT

Hauptverband der
gewerblichen
Berufsgenossenschaften

Europäisch notifizierte Stelle
Kenn-Nummer 0340

Prüf- und Zertifizierungsstelle beim Fachausschuss Elektrotechnik,
Postfach 51 05 80, 50941 Köln

Danfoss Solar Inverters
PowerLynx A/S
Jyllansgade 28
6400 Sønderborg
Denmark

Ihre Zeichen/Ihre Nachricht vom	Unser Zeichen (bitte stets angeben)	Bearbeiter	☎ (02 21) 37 78-	Datum
	UB.010.17	PI/Ow	6312	23.08.2007

Statement of Compliance

Product: Automatic Disconnection Device

Type: PGI ENS 2

Intended Use: The automatic disconnection device is used as a safety interface between the generator and the public low-voltage distribution net. It serves as a replacement for a disconnection switch which is accessible to the distribution net operator at all times.

The device is integral part of the PV-converters:
ULX 1800i, ULX 1800o, ULX 3600i,
ULX 3600o, ULX 5400i, ULX 5400o.

Standard: DIN V VDE V 0126-1-1 "Automatic disconnection device between a generator and the public low-voltage grid" (2006-02)

The device fulfils the normative requirements of the above mentioned standard for the intended use. This statement is based on the test-report Az.: LB.010.00/3-2388 of 9/2004 and 20/2006.

This document is valid until:

31.12.2010

- Mehlem -
Head of Test- and
Certification Body

